

SYSTEMS for INDUSTRY

DETROIT, MICHIGAN

PITOT TUBE INSTALLATION AND WIRING DIAGRAM FOR D/P TRANSMITTER FOR AIR/GAS or STEAM.

NOTE: THIS DRAWING IS FOR
AIR/GAS & STEAM SERVICE IN A HORIZONTAL
PIPE.
THE TRANSMITTER SHOULD BE MOUNTED
ABOVE THE PIPE, AND THE SIGNAL LINES
SHOULD HAVE AT LEAST (1") PER FOOT
UPSLOPE. THE AMBIENT TEMPERATURE
OF THE TRANSMITTER CANNOT EXCEED
120 DEGREES F.

