

# SYSTEMS for INDUSTRY DETROIT, MICHIGAN

Pitot tube, Condensate Pots & D/P Transmitter Installation  
in a Horizontal Steam line.

## HORIZONTAL STEAM LINE

Signal lines from sensor to the condensate pots  
should have at least 1 inch per foot upslope.

