

# 2" PIPE MOUNTING OF D/P TRANSMITTER & 3-VALVE MANIFOLD

UP




TUBING TO SENSOR



USE 1/4" BY 2" HEX BOLTS PROVIDED WITH MANIFOLD, AND MOUNT MANIFOLD ONTO BRACKET USING THE TWO THREADED HOLES.



MOUNT D/P TRANSMITTER TO MANIFOLD WITH 7/16" FINE THREAD HEX BOLTS PROVIDED WITH MANIFOLD.



NOT DRAWN TO SCALE