

SYSTEMS for INDUSTRY

DETROIT, MICHIGAN

PITOT TUBE INSTALLATION AND WIRING DIAGRAM FOR D/P TRANSMITTER

AIR/GAS SERVICE
INSTALLATION DRAWING
FOR SENSOR AND
TRANSMITTER

UP FLOW

IF THE TRANSMITTER IS LOCATED BELOW
THE SENSOR, THE SIGNAL LINES SHOULD
HAVE AT LEAST 1" PER FOOT DOWN SLOPE.

